


EXISTING HYDRANT BOOSTER

C DESIGN DEVELOPMENT TL 18.06.24 TL 28.02.24 B SCHEMATIC DESIGN A SKETCH PLAN TL 22.12.23 Rev Description Checked Approved Date Drafting Check

2500 5000 7500 10000 12500mm SCALE 1:250 AT ORIGINAL SIZE

SCALE 1:200 AT ORIGINAL SIZE





Conditions of Use. This document may only be used by GHD's client (and any other person who GHD has agreed can use this document) for the purpose for which it was prepared and must not be used by any other person or for any other purpose.



Project BATEMANS BAY COMMUNITY HEALTH Status PRELIMINARY

EXISTING FIP

ENTRY

Drawing COMBINED SERVICES SITE PLAN

12611726-GHD-00-00-DRG-CS-0

EXISTING CAMPUS MSB (BELOW)

TO PLANTROOM

- ED DB IN STORE ROOM

THEATER MECHANICAL PLANT

MEDICAL GAS STORAGE.
ADDITIONAL 02 MANIFOLD
PACKS PROPOSED FOR INTERIM
USAGE

- APPROX. AREA OF NEW  ${\rm O_2}$  MANPACKS TO MATCH PEAK

NOMINAL PATH OF EXISTING LPG PIPE. THIS BRANCH TO BOILER ROOM (TBC)

NOMINAL PATH OF EXISTING

HOSPITAL ELECTRICAL
MAINS CABLE. DEPTHS TO
BE VERIFIED PRIOR TO CAR

3000 L OXYGEN TANK TO BE DEMOLISHED

EXISTING LPG TANK TO BE

SEWER PUMP BELOW CONNECTING TO MORTUARY

PROPOSED SERVICE AREA BELOW BUILDING

NEW CENTRAL COMMS ROOM

NOMINAL PATH OF WATER EASEMENT AND PROPOSED SERVICE ACCESS PATH

DEMOLISHED

PARK CONSTRUCTION

DELIVERY LOAD

**Design Check**